

PHONE (618) 825-2715 FAX (618) 277-0482



10 PUBLIC SQUARE BELLEVILLE, ILLINOIS 62220-1623 www.co.st-clair.il.us

SOLAR INSPECTIONS

*ROUGH-IN: Is to be inspected when the panels are in place on support system with wiring installed to inverter boxes. **Ground mounts must have the trench inspected prior to filling** (can be filled if a portion is left open for inspection).

***SERVICE:** Is to be inspected when wiring is connected to house panel or when line side tap is being connected to power company wiring in meter can. (DO NOT CUT AMEREN SEAL).

*FINAL: Is to be inspected when project is complete and ready for power up.

*****PLEASE NOTE: FOR ROUGH IN/SERVICE HOMEOWNER MUST BE HOME FOR ENTRY INTO THE HOUSE FOR INSPECTION & A TECHNICIAN FROM YOUR COMPANY AS WELL****